

6 wells

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY


STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 100764

Permit No.

Basin 212



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30222

1. OWNER 7-Eleven Co Ken Hilliard ADDRESS AT WELL LOCATION 7-Eleven  
 MAILING ADDRESS P.O. Box 711 7291 S. Las Vegas Blvd  
Dallas, TX 75221 Las Vegas, NV

2. LOCATION SE 1/4 SE 1/4 Sec 5 T 20 N 61 E Clark County  
 PERMIT NO. 177-05-801-044 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Poorly graded sands		0	13	13
well graded sands		13	16	3
caliche		16	18	2
sandy clays		18	46	28
caliche		46	53	7
silty sands		53	55	2
caliche		55	56.5	1.5
clayey sands		56.5	62	5.5
well graded sands		62	67	5
clayey sands	112'	67	112	45

8. 112 WELL CONSTRUCTION  
 Depth Drilled 712 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)  
 From 7 5/8 Inches To 110 Feet  
 From 0 Feet To 110 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	SC40	PVC	0	80

Perforations:  
 Type perforation Factory Slotted  
 Size perforation .020  
 From 80 feet to 110 feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 75

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 75 feet to 110 feet

9. WATER LEVEL  
 Static water level 112' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 8/14/2006  
 Date completed 8/24/2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WDC Exploration & Wells Contractor  
 Address 570 Corinthian Way Contractor  
N. Las Vegas, NV 89030  
 Nevada contractor's license number issued by the State Contractor's Board 0012852  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2057  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 9/20/06