

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 100776  
 Permit No. \_\_\_\_\_  
 Basin 213

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30323

1. OWNER **3700 ASSOCIATES LLC**  
 MAILING ADDRESS 667 MADISON AVE  
NEW YORK, NY 10021-8029

ADDRESS AT WELL LOCATION 3698 S. LAS VEGAS BLVD.  
LAS VEGAS, NV

2. LOCATION SW 1/4 NE 1/4 Sec 20 T 21 S R 61 E CLARK County  
 PERMIT NO. DW1220A 162-20-603-007  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE (DEWATER)  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<b>14-Dewatering wells</b>				
Asphalt		0'	3"	3"
Brown dirt		3"	8'	7'-9"
Caliche		8'	14'	6'
Brown silt	xx	14'	17'	3'
Brown silty clay		17'	21'	4'
White clay		21'	26'	6'
Red clay		26'	28'	2'
Brown clay		28'	34'	6'
White silty clay		34'	41'	7'
Brown clay & small rock		41'	50'	9'
Red clay		50'	53'	3'
White clay		53'	59'	6'
Brown clay		59'	65'	6'
White clay		65'	72'	7'

8. WELL CONSTRUCTION  
 Depth Drilled 72 Feet Depth Cased 72 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
24" Inches 0 Feet 72 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation Machine  
 Size perforation .25"x2.5x3 rows @13  
 From 0 feet to 72 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 0 feet to 72 feet

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 8/11, 20 06  
 Date completed 9/12, 20 06

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ALLEN DRILLING INC.  
 (CONTRACTOR)  
 Address 4015 WEST TOMPKINS AVE.  
 (CONTRACTOR)  
LAS VEGAS, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2231  
 Signed Victor Allen Esten  
 By driller performing actual drilling on site or contractor  
 Date 9/14/06