

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 100786
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30243

1. OWNER Vern Miller
 MAILING ADDRESS _____
 ADDRESS AT WELL LOCATION 251 W. Nopah Vista Ave.

2. LOCATION NE 1/4 NE 1/4 Sec 16 T 19S N R 53 E Nye County
 PERMIT NO. 29-214-02 Country Place II Ut:1, Blk:2, Lot:7

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Loam		0	28	28
Brown Clay		28	73	45
Brown Clay/Caliche		73	77	4
Brown Clay		77	92	15
Brown Clay/Caliche		92	97	5
Brown Clay	X	97	200	103

DCNR/DWR RECEIVED
 SEP 14 2006
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches _____ Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.92	.28	0	200

Perforations:
 Type perforation Saw Cut
 Size perforation 1/4" width 8" long
 From 160 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: _____
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 82 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name JIM PIKE WELL DRILLING, LLC.
 (CONTRACTOR)

Date started September 6, 20 06
 Date completed September 6, 20 06

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.			
<u>20</u>		<u>4</u>	<u>1/4</u>

Address P.O. BOX 56
 (CONTRACTOR)
PAHRUMP, NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 17563A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1324
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date September 11, 2006