



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

*Amended*

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30388

1. OWNER DOUGLAS EIGNOR ADDRESS AT WELL LOCATION 320 E EMBER ST  
 MAILING ADDRESS 320 E EMBER ST  
PAHRUMP, NV

2. LOCATION NE 1/4 SW 1/4 Sec. 34 T 20S N/S R 53E E NYE County  
 PERMIT NO. 40-683-08 CALVADA VALLEY UNIT 4A  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To  | Thick-ness |
|----------|--------------|------|-----|------------|
| CLAY     |              | 0    | 101 | 101        |
| CALICHE  | WB           | 101  | 107 | 6          |
| CLAY     |              | 107  | 136 | 29         |
| CALICHE  | WB           | 136  | 138 | 2          |
| CLAY     |              | 138  | 162 | 24         |
| CALICHE  | WB           | 162  | 168 | 6          |
| CLAY     |              | 168  | 184 | 16         |
| CALICHE  | WB           | 184  | 186 | 2          |
| CLAY     |              | 186  | 200 | 14         |

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet  
 From 0 Feet To 200 Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|--------------------|-------------------------|-------------|-----------|
| 6                  | 3.63               | .250                    | 0           | 200       |

Perforations:  
 Type perforation SAWCUT  
 Size perforation 1/8 X 3

From 140 feet to 200 feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 67 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor  
 Address 1220 E MANSE RD Contractor  
PAHRUMP, NV, 89048  
 Nevada contractor's license number issued by the State Contractor's Board 47333  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 10/3/2006

Date started 10/2/2006, 19  
 Date completed 10/2/2006, 19

7. WELL TEST DATA

| TEST METHOD:  | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift |        |                               |              |

**DGNR/DWR RECEIVED**

**OCT 13 2006**

**LAS VEGAS OFFICE**