STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 100902
Permit No.
Basin 048

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56180

1. OWNER TRAVIS YOCUM
MAILING ADDRESS 382 MARINO
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION 108 BARTLESS DRIVE
Subdivision Name:
County: ELKO

2. LOCATION ~~NW~~ ¼ SW ¼ Sec 2 T 02N N/S R 56 E
PERMIT/WAIVER No. 006-30A-020
Issued by Water Resources Parcel No.

Latitude 40.77102.N
Longitude 115.64056.W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SOFT SANDSTONE		0	20	20
HARD SANDSTONE		20	28	8
CLAY		28	32	4
GRAVEL	X	32	38	6
SOFT SANDSTONE		38	92	54
GRAVEL & SAND	X	92	95	3
HARD STONE		95	120	25

Date started: ~~23 Sep~~ 7-26 , 20 06
Date completed: ~~12 Nov~~ 7-31 , 20 06

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	19
6	SDR-21		19	120

Perforations:
Type of perforation SCREEN
Size of perforation 0.032
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 19 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout 19 to 51 ☒ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 51 to 120 ☐ Pumped ☒ Poured
Type: 3/8 PEA GRAVE;
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 35 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	80	148	

STATE ENGINEERS OFFICE
2006 AUG 25 PM 1:52
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. dba FERTIG DRILLING COMPANY
Contractor
Address P.O. BOX 525
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 031904
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1584
Signed
By driller performing actual drilling on site of contractor
Date 8-20-06

(Rev. 05-00)

USE ADDITIONAL SHEETS IF NECESSARY