WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 100907
Permit No.
Basin 104

NOTICE OF INTENT NO. 58061

1. OWNER K&S Properties / A California Partnership
MAILING ADDRESS 3130 Air Way Avenue
Costa Mesa, CA 92626

ADDRESS AT WELL LOCATION 5650 South Carson St.
Carson City, NV. (old Bodines Resturant location)

2. LOCATION SE 1/4 SE 1/4 Sec. 31 T 15N N/S R 20E E Carson County
PERMIT NO. Issued by Water Resources | Parcel No. 09-303-08 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
4" well GPS location 39 degrees 6.939 north and 119 degrees 46.421 west. Measured water level at 10.1' and measured depth at 32'. Installed tremme pipe and cleaned well to 40'. We then pumped in approximately 1/2 yard of neat cement from bottom of well to surface.				
4" well GPS location39 degrees6.939 north and 119 degrees 46.417 west. Removed 21' of 1" drop pipe with submersible pump. Measured static water level at 10'. Installed tremme pipe and cleaned to 38'. We then pumped in approximately 1/2 yard of neat cement.				
Both of these 4" wells are also filed under the same intent card as the 6" well				
W6584				

Date started 7/17/2006, 19__
Date completed 8/23/2006, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
2006 SEP 12 AM 10:51
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 40' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		.188	40'	+1

Perforations:
Type perforation n/a
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 40'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 10' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Thompson (By driller performing actual drilling on-site or contractor)
Date 9/11/2006

USE ADDITIONAL SHEETS IF NECESSARY