WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101042
Permit No.
Basin 212

NOTICE OF INTENT NO. 29721

1. OWNER Rio Development Co., Inc.
MAILING ADDRESS One Hurrahs Ct.
Las Vegas, NV. 89119-4312

ADDRESS AT WELL LOCATION ON RD VILLA RICA DR. IN FRONT OF PARCEL

2. LOCATION NE ¼ SE ¼ Sec. 01 T. 23 N/S R. 61 E. Clark County
PERMIT NO. — Issued by Water Resources | Parcel No. 191-01-~~[illegible]~~-001 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL - SANDY GRAVEL		0	4	4
CALICHE		4	6	2
SANDY GRAVEL		6	15	9
SILTY SAND		15	18	3
SAND-w/gravel, SILT		18	20	2
SILTY SAND-w/gravel		20	23	3
CALICHE		23	25	2
SILTY SAND-w/gravel		25	27	2
SANDY GRAVEL		27	28½	1½
SILTY SAND-w/gravel		28½	31	2½

DCNR/DWR
RECEIVED
OCT 23 2006
LAS VEGAS OFFICE

Date started 9-25, 2006
Date completed 9-25, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 31 Feet Depth Cased 29 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
6	0	31

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Sch 40	ASTM F480	0	29

Perforations:
Type perforation Factory Slots
Size perforation .020
From 29 feet to 9 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 29 feet to 8 feet

9. WATER LEVEL
Static water level No Water feet below land surface
Artesian flow Well Dry G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling (Contractor)
Address 4255 W. Post Rd. (Contractor)
Las Vegas, NV. 89118
Nevada contractor's license number issued by the State Contractor's Board 0054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1944
Signed Thomas M. Beall (By driller performing actual drilling on site or contractor)
Date 10-20-06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627