WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101044
Permit No.
Basin 117

NOTICE OF INTENT NO. 28883

1. OWNER James Horten
MAILING ADDRESS P.O. Box 287
Dyer, Nevada 89010

ADDRESS AT WELL LOCATION East Side Easy
~~[illegible]~~ ST. Lot #

2. LOCATION NW ¼ SE ¼ Sec. 6 T. 4 N/S R. 36 E. Esmeralda County
PERMIT NO. Issued by Water Resources | Parcel No. 007-71-004 | Subdivision Name Billy Wright

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown silt sand	0	6	6	6
Brown clay sandy		6	28	22
Brown clay 1/4" gravel		28	35	7
Brown clay sticky		35	60	25
Brown clay 1/4 gravel		60	80	20
Rocks & course sand	x	80	140	60
Brown clay		140	154	14
Rocks & sand	x	154	177	23
Tan clay		177	181	4
Gravel	x	181	234	53
Sand		234	236	2
Gravel	x	236	254	17
Brown sticky clay		254	261	7
Brown clay & gravel		261	268	7

OCNR/DWR
RECEIVED
OCT 18 2006
LAS VEGAS OFFICE

Date started 8-9-06, 2006
Date complated 9-18-06, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
120	170	1
100	126	.5
25	26	.5

8. WELL CONSTRUCTION
Depth Drilled 268 Feet Depth Cased 256 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 268 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	sdr 21	PVC 5/16	12	256
6 5/8	Steel	.188	0	12

Perforations:
Type perforation Saw Cut horazonal
Size perforation 2 rows X .1 X 3"
From 136 feet to 256 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 268 feet

9. WATER LEVEL
Static water level 74 feet below land surface
~~[illegible]~~ 120 G.P.M. P.S.I.
Water temperature 60 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Russell Kile
Contractor
Address 22893 HWY 6
Contractor
Benton, CA. 93512

Nevada contractor's license number issued by the State Contractor's Board 039576
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 123-8
Signed Russell Kile
By driller performing actual drilling on site or contractor
Date 9-18-06

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 12-01) (O)-627