WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101059
Permit No.
Basin 177

NOTICE OF INTENT NO. 56158

1. OWNER FREHNER CONSTRUCTION COMPANY
MAILING ADDRESS 4040 FREHNER ROAD
LAS VEGAS, NV 89030

ADDRESS AT WELL LOCATION CLOVER VALLEY BASIN

2. LOCATION NW 1/4 NW 1/4 Sec. 34 T 36N N/S R 62E E ELKO County
PERMIT NO. C-237 (Issued by Water Resources) Parcel No. Lat 40.96611 N Long 114.96055 W NAD 83 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. Const X PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND/GRAVEL		0	12	12
LIMESTONE		12	30	18
QUARTZ		30	70	40
LIMESTONE		70	120	50
GRAVEL	X	120	131	11
QUARTZ & SAND		131	150	19
GRAVEL & SAND	X	150	170	20
LIMESTONE		170	180	10
GRAVEL	X	180	185	5
SAND	X	185	200	15

Corrected as per X conversation w/Fertig 4/25/2007 MC

Date started 9/10/2005, 19__
Date completed 9/12/2005, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	80		4.5

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		188	+2	18
6	SDR-17		0	200

Perforations:
Type perforation SCREEN
Size perforation .050
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes ~~[X] No~~
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

Seal Type:
[ ] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
Bentonite 50-Surface

9. WATER LEVEL

Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING CO.
Contractor

Address P.O. BOX 525
Contractor

ELKO, NEVADA 89803

Nevada contractor's license number issued by the State Contractor's Board 031904

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 10/3/2005

USE ADDITIONAL SHEETS IF NECESSARY