

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY

Log No. 101101
 Permit No. _____
 Basin 069
 NOTICE OF INTENT NO. 55631

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 511.010 and NAC 534.340

1. OWNER **Karen Young and Kim Michelle Kleider**
 MAILING ADDRESS **PO Box 4204**
Hilo, HI 96720
 ADDRESS AT WELL LOCATION **Paradise Hills Road**
Paradise Hills Estates

2. LOCATION **SE 1/4 NE 1/4 Sec 35 T 40 N R 38 E** Humboldt County
 PERMIT NO. **NE 5E 06-455-01**

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------------|--------------|------|-----|------------|
| Sand | | 0 | 2 | 2 |
| Clay | | 2 | 20 | 18 |
| Sand & Gravel | | 20 | 45 | 25 |
| Clay | | 45 | 40 | 5 |
| Fine Gravel | x | 40 | 95 | 55 |
| Clay | | 95 | 100 | 5 |
| Sand & Gravel | | 100 | 115 | 15 |
| Clay | | 115 | 120 | 5 |
| Sand & Gravel | x | 120 | 145 | 25 |
| Coarse gravel and sand | x | 145 | 160 | 15 |

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet
160 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6.5/8 | 10 | 188 | +1 | 20 |
| 6.625 | 4.06 | .316 | 20 | 160 |

Perforations:
 Type perforation **Factory cut**
 Size perforation **0.50**
 From 140 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 60 feet to 160 feet

9. WATER LEVEL
 Static water level 59 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started June 5, 20 06
 Date completed June 8, 20 06

Name **Fred Anderson & Sons Drilling, Inc.**
 (CONTRACTOR)
 Address **10760 Grass Valley Road**
 (CONTRACTOR)
Winnemucca, NV 89445
 Nevada contractor's license number 021467
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2083
 Division of Water Resources/the on-site driller

7. WELL TEST DATE

| TEST METHOD: | Bailer | Pump | Air Lift |
|-------------------------------|--------------------------|--------------------------|-------------------------------------|
| G.P.M. | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Draw Down (Feet Below Static) | | | |
| Time (Hours) | | | |
| <u>40</u> | | | <u>4</u> |

Signed _____
 By driller performing actual drilling on site or contractor
 Date June 27, 2006