COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101102
Permit No.
Basin 069
NOTICE OF INTENT NO. 55646

1. OWNER Janet & Graydon Kennedy
MAILING ADDRESS 3305 Park Manor
Hilo, HI 96720

ADDRESS AT WELL LOCATION Martin Creek Road
Paradise Valley, NV 89426

2. LOCATION ¼ SE ¼ Sec 15 T 42 N R 40 E Humboldt County

PERMIT NO. 004-601-14
Permit No.

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand/Clay		0	10	
Corse Sand		10	20	
Corse Gravel	x	20	50	
Sand		50	65	
Cobles & Gravel		65	85	
Gravel		85	110	
Clay & Sand		110	115	
Gravel & Cobles		115	140	
Corse Gravel		140	195	
Clay		195	200	
Cobles & Gravel		200	250	
Clay		250	260	
Sand & Gravel	x	260	285	
Cobles		285	305	
Sand & Gravel	x	305	315	

Date started June 10, 20 06
Date completed June 13, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		4

8. WELL CONSTRUCTION

Depth Drilled 315 Feet Depth Cased 315 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	315 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	315

Perforations:
Type perforation Factory cut
Size perforation 3/32x4'
From 275 feet to 315 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100' ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 315 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow N/A G.P.M N/A P.S.I
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson & Sons Drilling, Inc. (CONTRACTOR)
Address 10760 Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed
By driller performing actual drilling on site or contractor
Date June 27, 2006

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com