WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101160
Permit No.
Basin 890

NOTICE OF INTENT NO. 58051

1. OWNER Douglas County Sewewr Improvement District
MAILING ADDRESS P.O. Box 578
Zephyr Cove, NV 89448

ADDRESS AT WELL LOCATION #1 Sewer Plant Road,
Zephyr Cove, NV.

2. LOCATION NW 1/4 NE 1/4 Sec. 23 T 13N N/S R 18E E Douglas County
PERMIT NO. Issued by Water Resources
1318000-001-008 Parcel No.
Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
2" well located at Sewer Plant: Measured static water level at 21.5' and depth of well at 42'. Installed 40' of 3/4" tremme pipe, mixed 4 bags of cement with 20 gallons of water and pumped thru tremme pipe from bottom of well to surface.				

Date started 6/22/2006 , 19__
Date completed 6/22/2006 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 42' Feet Depth Cased 42' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		sch.40	42'	0'

Perforations:
Type perforation slotted
Size perforation n/a
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 42'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 21.5' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump
Contractor
Address P.O. Box 20159
Contractor
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Trampe
By driller performing actual drilling on-site or contractor
Date 7/5/2006

USE ADDITIONAL SHEETS IF NECESSARY