WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 01172
Permit No.
Basin 103

NOTICE OF INTENT NO. 52879 P 52878

1. OWNER Sunshine Court
MAILING ADDRESS
ADDRESS AT WELL LOCATION 6270 Rio Vista
Washoe County

2. LOCATION SW ¼ ~~SE~~ NE ¼ Sec. 2 T. 14 N/S R. 20 E.
PERMIT NO. (Issued by Water Resources) Parcel No. 10-503-29 Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Deepen [ ] Replace [ ] Abandon [ ] Recondition [ ] Other

4. PROPOSED USE: [X] Domestic [ ] Municipal/Industrial [ ] Irrigation [ ] Monitor [ ] Test [ ] Stock

5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand Rock | | 0 | 12 | 12 |
| Sand Gravel Clay | | 12 | 95 | 83 |
| Decomposed Granite | | 95 | 145 | 50 |
| Dr. Fractured Rock | X | 145 | 240 | 95 |
| Gravel Clay | X | 240 | 275 | 35' |

Date started 4-6-05
Date completed 4-15-05

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 15 | NA | 2.5 hrs |

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 200 Feet |
| 9 7/8 Inches | 200 Feet | 275 Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | +1 | 20 |
| SDR 21 6" | | | 20 | 275 |

Perforations:
Type perforation Hand cut
Size perforation 1/40 x 3
From feet to feet
From 240 feet to 275 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 100 feet to 275 feet

9. WATER LEVEL
Static water level 190 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BLAIR PUMP CO. INC. Contractor
Address P.O. Box 2255 Contractor
Carson City, NV 89702

Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2256
Signed [signature] by driller performing actual drilling on site or contractor
Date 4-25-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O) 627

2006 JAN 25 PM 2:15