WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101175
Permit No.
Basin 103

NOTICE OF INTENT NO. 56704

1. OWNER Henry Hoppe
MAILING ADDRESS
ADDRESS AT WELL LOCATION 114 Sam Clemens

2. LOCATION NE ¼ NE ¼ Sec. 30 T. 17 N/S R. 22 E. ~~[illegible]~~ Storey County
PERMIT NO. (Issued by Water Resources) 114 SAM Clemens (Parcel No.) .003 282-05 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cobble		0	120	120
Small Gravel & Sand		120	215	95
Clay & Small Gravel		215	280	65
Wet Clay		280	295	30
Wet Clay Lg Gravel		295	310	15
5% Wet Brown Clay		310	340	30
Sand and Lg Gravel				

Date started 10-31, 2005
Date completed 11-04, 2005

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		4 hrs

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	340 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	20
6 5/8		SDR 21	20	340

Perforations:
Type perforation Grinder cut
Size perforation 1/8 inch
From 300 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From ~~[illegible]~~ 50 feet to 340 feet

9. WATER LEVEL
Static water level 260 feet below land surface
Artesian flow NA G.P.M. ~~[illegible]~~ 15 P.S.I.
Water temperature 60 °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BLAIN DRILLING & PUMP CO. INC. (Contractor)
Address P.O. Box 1255 Carson City, NV 89702

Nevada contractor's license number issued by the State Contractor's Board 44757
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2134-[illegible]
Signed [signature] By driller performing actual drilling on site or contractor
Date 11-04-05

(Rev. 12 01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

RECEIVED
2005 NOV 10 PM 3:39
STATE ENGINEERS OFFICE

2006 JAN 25 PM 2:15