

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT



office use only
 Log No. 101184
 Permit No.
 Basin 087

NOTICE OF INTENT NO 56427

1. OWNER **Herbert Beck**
 MAILING ADDRESS **1405 Foothill Road**
Reno, NV

ADDRESS AT WELL LOCATION **1405 Foothill Road**

2. Location **NE 1/4 NW 1/4 Sec 18 T 18 N R 20E Washoe County**
 PERMIT NO. **PARCEL NO. 044-391-12** SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	<input checked="" type="checkbox"/> Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	Mud

6. LITHOLOGIC LOG					8. WELL CONSTRUCTION					
Material	Water Strata	From	To	Thickness	Depth Drilled	HOLE DIAMETER (BIT SIZE)	Depth Cased	From	To	
Bailed well to 115'				0'	11'	inches	0'	feet	116'	
Perfed from 50 to 115'				0'		inches		feet	feet	
Installed termie to 116' & pumped neat cement to surface.				0'		inches		feet	feet	
					CASING SCHEDULE					
					0'	Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
					0'	6 5/8	12.94	188	+1 1/2	116
					0'	Perforations:				
					0'	Type Perforation	Mills Knife			
					0'	Size perforation	1/4 x 3			
					0'	From	50	feet to	116	feet
					0'	From		feet to		feet
					0'	From		feet to		feet
					0'	From		feet to		feet
					0'	From		feet to		feet
					0'	From		feet to		feet
					0'	Surface Seal	<input checked="" type="checkbox"/> YES	No	Seal Type:	
					0'	Depth of Seal	116	feet	<input checked="" type="checkbox"/> Neat Cement	
					0'				<input checked="" type="checkbox"/> Cement Grout	
					0'				<input type="checkbox"/> Poured	
					0'				<input type="checkbox"/> Concrete Grout	
					0'	Gravel Packed:	Yes	No		
					0'	From		feet to		feet
					0'	9 WATER LEVEL				
					0'	Static water level	98'	feet below land surface		
					0'	Artesian flow	0	GPM	0	P.S.I.
					0'	Water Temperature	cold	Degrees F	Quality	

Date started **12-7 -05**
 Date completed **12-7 -05**

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
 NV Contractors No. **14170**
 NV Driller's Lic (on site) **2187**
 Signed *Stan McKay*
 By driller performing actual drilling on site or contractor
 Date **12-13 -05**

01 DEC 27 11 40 AM '69

2085 DEC 27 AM 11:40

11 40