


STATE OF NEVADA
DIVISION OF WATER RESOURCES



OFFICE USE ONLY

Log No. 101190
Permit No. _____
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please fill in this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57197

1. OWNE Ron Evans
MAILING ADDRESS 1888 W Gummow Fallon, NV 89406
Fallon, NV 89406

ADDRESS AT WELL LOCATION 1888 W Gummow Dr.
Fallon, NV 89406

2. LOCATION SE 1/4 NW 1/4 Sec 23 T 19 R 26
PERMIT NO _____ Parcel No. 008-252-06

Latitude 39.49872 Longitude -118.8037 WGS 84
Subdivision Name _____ County _____

3. WORK PERFORMED
New Well

4. PROPOSED USE
Domestic

5. WELL TYPE
Rotary-mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	4	4
Brown Clay		4	18	14
Brown Sand		18	38	20
Gray Sand		38	72	34
Brown Clay		72	74	2
Brown Sand	X	74	104	30

8. WELL CONSTRUCTION

Depth Drilled 104 Depth Cased 104 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12.3 Inches	0 Feet	50 Feet
10 Inches	50 Feet	104 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (inches)	Weight/Pt. (Pounds)	Wall Thickness	From (Feet)	To (Feet)
6.625	12.92	0.188	0	20
6	3.85	0.258	20	104

Perforations:

Type perforation Saw Cut
Size perforation 0.125
From 99 feet to 104 feet

Surface Seal Yes No

Seal Type:

Depth of Seal 50

Concrete Grout

Placement Method: Pumped

Gravel Packed: Yes No

From 50 feet to 104 Feet

9. WATER LEVEL

Static Water Level 8 feet below land surfac

Artesian Flow G.P.M. P.S.I.

Water temperature ° F Qualit unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.

Contractor

Address 403 McLean Road

Fallon, NV 89407

Contractor

Nevada contractor's license number 29064
issued by the State Contractor's

Nevada driller's license number issued by the 2307
Division of Water Resources the on-site driller

Signe

By driller performing the actual drilling on site or contract

Date 4/18/2006

Date started 4/6/2006

Date completed 4/6/2006

7. WELL TEST DATA

TEST METHOD

Comments	GPM	Drawdown	Time (Hours)

2009 APR 29 PM 1:08

1000000000