

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 101201  
 Permit No. \_\_\_\_\_  
 Basin 093

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **55356**

1. OWNER Vince Cannizaro  
 MAILING ADDRESS 1215 Serperntine Rd.  
Reno, NV 89506  
 ADDRESS AT WELL LOCATION 1215 Serperntine Rd.  
Reno

2. LOCATION SW 1/4 NW 1/4 Sec. 14 T 22N N/S R 19E E Washoe County  
 PERMIT NO. 079-481-56  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Sandy brown clay		1	6	5
Soft brown sand		6	9	3
Sandy clay some gravel		9	31	22
Cement sands & gravel		31	51	20
Soft zone		51	53	2
Brown sandy clay		53	93	40
Soft zone		93	99	6
Brown sandy clays		99	121	22
Soft zone		121	123	2
Brown sandy clays		123	153	30
Soft zone		153	156	3
Brown sandy clay		156	221	65
Soft zone	x	221	226	5
Brown sandy clays		226	229	3
Soft zone	x	229	233	4
Brown sandy clay		233	241	8
Soft zone	x	241	243	2
Brown rusty sandy clay		243	257	14
Soft zone	x	257	261	4
Brown sandy clay		261	275	14

Washoe County Well Permit # WL 040302

8. WELL CONSTRUCTION  
 Depth Drilled 275 Feet Depth Cased 275 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 275 Feet  
11 Inches  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>275</u>

Perforations:  
 Type perforation Machine Cut  
 Size perforation 3/32 x 3  
 From 210 feet to 270 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 275 feet

9. WATER LEVEL  
 Static water level 100 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Not tested

Date started 8/16/2005, 19  
 Date completed 8/24/2005, 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:	
	G.P.M.	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	Draw Down (Feet Below Static)	
	<u>15</u>	<u>6</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Bruce MacKay Pump & Well Service, Inc. Contractor  
 Address 1600 Mt. Rose Hwy Contractor  
Reno, NV 89511  
 Nevada contractor's license number issued by the State Contractor's Board 23096  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed R. Bruce MacKay  
 By driller performing actual drilling on-site or contractor  
 Date 8/25/2005

RECEIVED  
JULY 19 1960  
ST. LOUIS, MISSOURI