WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101207
Permit No.
Basin 102

NOTICE OF INTENT NO. 52875 52875

1. OWNER Keith Wells
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1485 E Badger

2. LOCATION SW ¼ NW ¼ Sec. 19 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) Parcel No. 17-424-16 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	20	20
Clay - SAND		20	100	80
Clay - Gravel		100	150	50
Gravel - Clay	X	150	180	30

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
11	0	180

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.187	+1	20
6"		SDR 21	20	18

Perforations:
Type perforation Grinder cut
Size perforation 1/8
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BLAIN DRILLING & PUMP CO. INC. (Contractor)
Address P.O. Box 1255 Carson City, NV 89702
Nevada contractor's license number issued by the State Contractor's Board 46498
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2226
Signed Jeff Yard (By driller performing actual drilling on site or contractor)
Date 3-22-05

Date started 3-21, 2005
Date completed 3-22, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	NA	2.5 hours

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627