COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101234
Permit No.
Basin 105

NOTICE OF INTENT NO. 58209

1. OWNER JACK WHITE CONSTRUCTION
MAILING ADDRESS 423 CLAIRE CT
GARDNERVILLE, NV 89460

ADDRESS AT WELL LOCATION 1162 JO LANE
GARDNERVILLE, NV89410

2. LOCATION NW ¼ ~~NE~~ NW ¼ Sec 12 T 12 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | Parcel No 1220-12-111-003 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
GRAVELS AND CLAY		3	89	86
BGOWN CLAY7		89	135	46
SMALL GRAVELS		135	182	47
BROWN CLAT		182	205	23
FRACTURED GRAVELS	XX	205	260	44
SMALL CLAY STRATAS				
GPS INFO:				
38.92417*N				
119.609089*W				
NAO 83				

Date started 7/9, 20 06
Date completed 7/12, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	49	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 260' Feet Depth Cased 260' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	260 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr21	4.24	.216		

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 220 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 60 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 60 feet to 260 feet

9. WATER LEVEL
Static water level 135 feet below land surface
Artesian flow G.P.M 35 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 7/21/06

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429