

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 101305
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27382

1. OWNER Gary Sellers ADDRESS AT WELL LOCATION
MAILING ADDRESS 8000 W Lakemead Pkwy Henderson, NV. 89015
2. LOCATION SW 1/4 SW 1/4 Sec 12 T 22 N R 62 E Clark (11-679218 E) County
PERMIT NO. 17812101005 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED: New Well, Replace, Recondition, Deepen, Abandon, Other
4. PROPOSED USE: Domestic, Municipal/Industrial, Irrigation, Test, Monitor, Stock
5. WELL TYPE: Cable, Rotary, RVC, Air, Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand w/ silt		0'	5'	5'
silty sand		5'	15'	10'
silty sand w/ caliche		15'	25'	10'
sand w/ silt		25'	30'	5'
sand clay silt		30'	40'	10'
sandy silt		40'	45'	5'
sandy clayey silt		45'	60'	15'
clay		60'	74'	14'
sand		74'	75'	1'
clay		75'	130'	55'

cemented in 16" casing 10'-0'
cemented 10" casing 70'-0'
GPS = N 36°-02.600' @ 1800' elev
W 115°-00.476'
DATUM = NAD83

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
22"	0'	10'	
14 3/4"	10'	70'	
8"	70'	124'	
6"	124'	130'	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	Sch 80	.674	123.5	120'
4.5	Sch 80	.674	106.0	0'

Perforations:
Type perforation factory
Size perforation 0/0
From 120' feet to 100' feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 95' Cement Grout Concrete Grout
Placement Method: Pumped ben grow 825 Cement Grout
 Poured 3/8 chips 130-130-120-10x20-120-97
Gravel Packed: Yes No 95-82 #60-97-95
From 120' feet to 95' feet

Date started 9-20, 2006
Date completed 9-28-06, 2006

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.			
Draw Down (Feet Below Static)			
Time (Hours)			

DCNR/DWR RECEIVED
OCT 20 2006
LAS VEGAS OFFICE

9. WATER LEVEL
Static water level 52' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Contractor
Address 7773 W Seldon Ln. Peoria, AZ 85345 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2250
Signed Dennis R Reed By driller performing actual drilling on site or contractor
Date 9-28-06