WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101317
Permit No.
Basin 209

NOTICE OF INTENT NO. 24713

1. OWNER CLARK BINGHAM
MAILING ADDRESS 6411 W. DEER SPRINGS WAY, LAS VEGAS NV 89131
ADDRESS AT WELL LOCATION 1.2 MILES NORTH ON RICHARDVILLE RD ALAMO NV 89001

2. LOCATION NE ¼ NE ¼ Sec. 30 T. 6-S N/S R. 61 E E. LINCOLN County
PERMIT NO. R-1295 (Issued by Water Resources) 011-170-05 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & BOULDERS		0	12	12
SAND & GRAVEL		12	21	9
FIRM CEMENTED SAND & GRAVEL		21	27	6
SAND & GRAVEL WET		27	34	7
OLIVE GREEN SANDY CLAY		34	40	6

DCNR/DWR RECEIVED
OCT 24 2006
LAS VEGAS OFFICE

Date started 10-01-2006, 19
Date completed 10-07-2006, 19

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5	13	2 HRS

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"		FAGLE-LOC	GL.	40

Perforations:
Type perforation VERTICAL
Size perforation 1/8" x 6" x 4 ROWS
From 20 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 18
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 40' feet to 18 feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 62 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RCBB INC (Contractor)
Address 6411 DEER SPRINGS WAY (Contractor)
LAS VEGAS NV 89131
Nevada contractor's license number issued by the State Contractor's Board 0020301
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2064
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-14-06

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627