STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101344
Permit No.
Basin 108

NOTICE OF INTENT NO. 57373

1. OWNER Don Tibbals
MAILING ADDRESS 56 State Route 339
Yerington, NV 89447

ADDRESS AT WELL LOCATION
Yerington, NV

2. LOCATION SW ¼ NW ¼ Sec 15 T 13N N/S R 25 E
PERMIT/WAIVER No. 70911 *Issued by Water Resources* Parcel No.

Latitude N38.99185 Longitude W119.18050
UTM E N Lyon
☒ NAD 27 ☐ NAD 83/WGS 84
Subdivision Name: *County:* Lyon

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other.....

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other .....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	5
Sand		5	15	10
Clay		15	20	5
Sand and Gravel Cobbles		20	45	25
Brown Clay w/some Gravel		45	50	5
Sand and Gravel		50	65	15
Sand and Gravel w/Cobbles		65	80	15
Sand & Gravel		80	130	50
Green and White Rock		130	150	20
Brown Rock with Green (Copper)		150	260	110

38.99185 °N
119.18050 °W
NAD27

Date started 5/30/2006 , 20
Date completed 6/4/2006 , 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pumping Level 119'	800	110	8.5

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	0	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.250	+2	100

Perforations:
Type of perforation Mill slot
Size of perforation 0.09
From 100 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 260 feet

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 9' feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hydro Resources Nevada Inc. dba Humboldt Drilling & Pump Company, Inc
Contractor
Address 4975 W. Winnemucca Blvd.
Contractor
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* 56797
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1713
Signed C. Jaynes Office
By driller performing actual drilling on site or contractor
Date 10/9/2006

STATE ENGINEERS OFFICE
2006 OCT 11 AM 11:37
RECEIVED

(Rev. 12-05)

USE ADDITIONAL SHEETS IF NECESSARY