

Log No. 101361
 Permit No. _____
 Basin 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58138

1. OWNER R + A Development ADDRESS AT WELL LOCATION 301 Angstrom
 MAILING ADDRESS 395 Sardinville Circle, Sardinville Nev. 89444
 2. LOCATION S 1/2 1/4 NE 1/4 Sec 22 T 23 E N/S R. 23 E County Lyons
 PERMIT NO. 009-251-17 Parcel No. _____ Subdivision Name Smith Vista
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
top soil		0	2	2
clay + gravel		2	16	14
sand + brown clay		16	40	24
brown clay + gravel		40	70	30
quartzite fine sand	yes	70	110	40
coarse gravel	yes	110	180	70
with water				
fine gravel		180	200	20
some clay				

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>188</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation factory saw slott
 Size perforation 3/32 x 180
 From 160 feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 60 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 60 feet to 200 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

Date started May 28, 2006
 Date completed May 31, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50+</u>	<u>20</u>	<u>3 hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edmund Miller Dilling Contractor
 Address PO Box 92 Smith Contractor
Nev. 89430
 Nevada contractor's license number 32166A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 718
 Division of Water Resources, the on-site driller
 Signed Edmund Miller
 By driller performing actual drilling on site or contractor
 Date June 28 - 06

2006 JUN 23 09:11:25

2006 JUN 23 09:11:25