


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY
Log No. 101363
Permit No. _____
Basin 107

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57502

1. OWNER Lynn Valentino ADDRESS AT WELL LOCATION 11 Gams Circle
MAILING ADDRESS 11 Gams Circle Smith, Nv 89430
Subdivision Name: N/A County: Lyon

2. LOCATION SE 1/4 NE 1/4 Sec 28 T 11N N/S/R 24 E Latitude _____ UTM E NAD 27
PERMIT/WAIVER No. 9-122-11 Longitude _____ N NAD 83/WGS 84
Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Old well 6 5/8 OD 207' deep				
Ream old casing		0	207	207
Fine to coarse sand		207	210	3
Well gravel & coarse sand & clay	X	210	225	15
Hard brown clay with coarse sand stratas		225	241	16
Coarse sand & small gravel	X	241	256	15
Brown clay		256	263	7
Fine to coarse sand		263	266	3
NOTE				
loss circulation no cuttings return		266	328	62
NOTE				
Small amts cutting return 50% circulation return				
Coarse sand & small gravel with clay stratas	XX	328	373	45
NOTE				
Static water level before drilling 127'				

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
373' 2"		373' 2"	

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
5 7/8	207		373' 2"

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	10.79	.188	3' 8"	373' 2"

Perforations:

Type of perforation	Factory screen
Size of perforation	3/32 X 3" 6 rows
From 333' 2"	feet to 373' 2"
From	feet to

Annular Seal: Yes No

<input type="checkbox"/> Neat Cement	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack: Yes No 3'8" to 373' 2" Pumped Poured

Type: _____

Bentonite Chips: Yes No to Pumped Poured

Type: _____

Date started: 27-Mar, 2006
Date completed: 7-Apr, 2006

7. Water Level
Static water level: 122' 8" feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: Cold °F
Quality: _____ Good

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
Air 20+	210' air line	1 hour	
Air 100+	370' air line	2 hours	

10. DRILLER'S CERTIFICATION


This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden Drilling Contractor
Address 152 N Bybee Lane Contractor
Yerington, Nv 89447

Nevada contractor's license number issued by the State Contractor's Board 57011
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634

Signed Larry Ogden
By driller performing actual drilling on site or contractor

Date 6/30/2006



STATE OF TEXAS

2006 JUN 30 PM 2:42