WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101372
Permit No.
Basin 105

NOTICE OF INTENT NO. 58056

1. OWNER Gardnerville Ranchos General Improvement Dist
MAILING ADDRESS 931 Mitch Drive
Gardnerville, NV 89423

ADDRESS AT WELL LOCATION At the corner of Riverview and Fairview in the Gardnerville Ranchos

2. LOCATION SW 1/4 SE 1/4 Sec. 10 T 12N N/S R 20E E Douglas County
PERMIT NO. 48752 Issued by Water Resources
Parcel No.
Gardnerville Ranchos Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Measured static water level at 13'. Measured depth of hole at 460'. Well was originally drilled to 598'. Spoke with Tim Hunt about fill in well and he suggested that we fill the well with concrete grout with the tremme pipe. We installed 450' of 2" tremme pipe and pumped in 8 yards of 6 sack sand mix grout. The 10" surface casing was removed after the well was full of cement.				

Date started 6/28/2006 , 19__
Date completed 6/29/2006 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 598' Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.5"	Inches	0	Feet	598'	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 460'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 13' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump
Contractor
Address P.O. Box 20159
Contractor
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Frampe
By driller performing actual drilling on-site or contractor
Date 7/11/2006

USE ADDITIONAL SHEETS IF NECESSARY