WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101373
Permit No.
Basin Ø87

NOTICE OF INTENT NO. 57806

1. OWNER Henrik Jorst
MAILING ADDRESS 2311 Diamond J Place
Reno, NV 89511

ADDRESS AT WELL LOCATION 3003 Holcomb Ranch Rd.

2. LOCATION NE 1/4 NW 1/4 Sec. 12 T 18N N/S R 19E E Washoe County
PERMIT NO. _____ Issued by Water Resources | 040-650-03 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| On this date we abandoned a 6 5/8 x .250 wall x 90' deep well. The well had been previously perforated from 90' to 40'. We perforated from 40' to 25' where we could no longer puncture the casing. We then pumped approximately 1.5 cu. yards of neat cement mixed 5.2 gal/sack using tremie pipe from the bottom to the top of the well. We then cut the top 2' off of the well. | | | | |
| Washoe County Permit #WL060145 | | | | |
| NAD83 | | | | |
| N 39.4450 | | | | |
| W 119.80031 | | | | |
| 139.445108° N | | | | |
| 119.799306° W | | | | |
| NAD27 Con USI | | | | |

RECEIVED 2006 OCT 17 AM 10:07 STATE ENGINEERS OFFICE

Date started 10/11/2006, 19__
Date completed 10/11/2006, 19__

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION

Depth Drilled 90 Feet Depth Cased 90 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 17.02 | .250 | 0 | 90 |

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 40 feet to 25 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc.
Contractor
Address 1600 Mt. Rose Hwy
Contractor
Reno, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271, 2299

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor

Date 10/11/2006

USE ADDITIONAL SHEETS IF NECESSARY