WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101388
Permit No.
Basin 10 DA

NOTICE OF INTENT NO. 57582

1. OWNER Mitch Gardner
MAILING ADDRESS Border Town Casino Inc. Cold Springs, NV, 19575
ADDRESS AT WELL LOCATION US 395 N, Frontage road, Cold Springs, NV

2. LOCATION NE ¼ SE ¼ Sec. 19 T. 21 N/S R. 18 E. Washoe County
PERMIT NO. FAC.ID. 4-000204 (Issued by Water Resources) NDOT ROW (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	4"	4"
Road base sand & gravel		4"	1½'	14"
fine sand fan		1½'	7'	5.5'
Silty sand		7'	29'	22'
Sandy silt	40'	29'	55'	26'
Nevada West Zone				
NAD 83/94				
~~UTM~~ State Plane				
~~N. 1441899.24~~ N 1991809 9.24				
E. 2226100.07				
39.671037°N				
119.998361°W				
NAD27 Conus				
MW-9				

Date started 8-29-06, 20
Date completed 8-29-06, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 55' Feet Depth Cased 55' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8½"	0	55'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		5.40	0'	35'

Perforations:
Type perforation Factory Slot
Size perforation .020
From 35' feet to 55' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 28'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Bentonite From 28-33'
Gravel Packed: ☒ Yes ☐ No
From 55' feet to 33' feet

9. WATER LEVEL
Static water level 40' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature <85° °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling Inc. (Contractor)
Address P.O. Box 940 (Contractor)
Meridian, ID 83680
Nevada contractor's license number issued by the State Contractor's Board C0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2188
Signed (By driller performing actual drilling on site or contractor)
Date 9-4-06

RECEIVED 2006 OCT 10 PM 1:32

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627