WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101390
Permit No.
Basin 069

NOTICE OF INTENT NO. 56585

1. OWNER Nevada Dept. of Agriculture
MAILING ADDRESS 350 Capitol Hill Ave. Reno, Nv 89502 775-688-1182
ADDRESS AT WELL LOCATION Well Located 40 Foot South of Shelton Lane and Right Bank of Big Cottonwood Ck., 1.7 mile E. of SR290.

2. LOCATION NW ¼ NW ¼ Sec. 30 T. 41 N/S R. 40 E. Humboldt County
PERMIT NO. MO 1421 Issued by Water Resources
Apn 04-47-132 Parcel No.
N/A Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black Clay Loam		0	4	4
Black Clay		4	12	8
Black Sandy Clay - Full of Coarse grit	12	12	16	4
Coarse Sandy Saturated mud		16	18	2
Gravelly Sandy Silty Mud Saturated		18	25	7

Date started September 26, 2006
Date completed September 26, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
GPS	Location	NAD 83
41	24.658	41.411082
		117.516548
117	31.051	NAD27 CONUS

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 24 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 5/8 Inches	0 Feet	25 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2-inch	PVC	Sch 40	0	24
	Flush	Threads		

Perforations:
Type perforation Slot
Size perforation 0.020 inch
From 14 feet to 24 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0 To 1 Foot
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 13 feet to 25 feet

9. WATER LEVEL
Static water level 8.95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Robert N. Pennington Contractor
Address 2730 N. Deer Run Rd Contractor
Carson City Nv 89701
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller EP 1857
Signed R.N. Pennington
By driller performing actual drilling on site or contractor
Date 10/2/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

RECEIVED
2006 OCT -5 AM 11:41
STATE ENGINEER'S OFFICE



INTERIOR-GEOLOGICAL SURVEY, RESTON, VIRGINIA-1989

2
2000
1
8000 9000 10 000

NEVADA

QUADRANGLE LOCATION

1	2	3
4		5
6	7	8

1 Santa Rosa Peak
2 Mullinix Creek
3 Spring City
4 Five Fingers
5 Little Poverty
6 Paradise Well
7 Willow Point
8 Hot Springs Peak

ADJOINING 7.5' QUADRANGLE NAMES

ROAD LEGEND

Improved Road . . . . . .
Unimproved Road . . . . . .
Trail . . . . . .

Interstate Route U.S. Route State Route

PARADISE VALLEY, NEVADA

PROVISIONAL EDITION 1988

41117-D5-TF-024

DARDS
DO 80225

RECEIVED
2006 OCT -5 AM 11:40
STATE ENGINEERS OFFICE

Shelton Lane Well
T41N R40E Sec.30 NW NW
APN 04-47-132
mo 1421
Notice of Intent # 56585



RECEIVED
2006 OCT -5 AM 11:40
STATE ENGINEER'S OFFICE