

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54158

1. OWNER Wayne Prouty ADDRESS AT WELL LOCATION 693 Foothill Rd, Gardnerville NV
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 SW 23 T. 12N N/S R. 19 E Douglas County
 PERMIT NO. 1217-23-002-009 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>dirt</u>		<u>0</u>	<u>3'</u>	<u>3</u>
<u>D-6 Sand & Boulders</u>		<u>3'</u>	<u>31'</u>	<u>28</u>
<u>D-6</u>		<u>31'</u>	<u>80'</u>	<u>49</u>
<u>Broker D-6</u>		<u>80</u>	<u>120</u>	<u>40'</u>
<u>38° 53.299N</u>				
<u>119° 48.983W</u>				
<u>48.983 W</u>				
<u>WG884</u>				
<u>38.88416 °N</u>				
<u>119.815386 °W</u>				
<u>NAD27</u>				

8. WELL CONSTRUCTION
 Depth Drilled 120' Feet Depth Cased 126' Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 120' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>.188</u>	<u>+6</u>	<u>FT 20'</u>
<u>6 5/8</u>	<u>PVC</u>	<u>SDR 21</u>	<u>20</u>	<u>120'</u>

Perforations:
 Type perforation Sawed
 Size perforation 1/8 x 4"
 From _____ feet to _____ feet
 From 100' feet to 120' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 60
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 60' feet to 120' feet

9. WATER LEVEL
 Static water level +6 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.00 °F Quality Clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Seach Drilling Inc Contractor
 Address PO Box 599 Contractor
Silver Springs NV 89429
 Nevada contractor's license number issued by the State Contractor's Board 31841
 Nevada driller's license number issued by the Division of Water Resources, the on site driller 1740
 Signed Nathaniel R. Seach
 By driller performing actual drilling on site or contractor
 Date 10/9/06

Date started Aug 30 2006
 Date completed 9/9 2006

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>100'</u>	<u>40' ft</u>	<u>2 hrs</u>	

RECEIVED

2005 OCT -9 PM 3: 18

STATE ENGINEERS OFFICE