

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30629

USA Corps of Engineers

1. OWNER BERND SCHMIOT ADDRESS AT WELL LOCATION 1W-01
 MAILING ADDRESS 4349 DUFFER DR. STE 1601 SITE ST-44
NELLIS AFB NEV. 89191-7007
 2. LOCATION NE 1/4 NE 1/4 Sec 9 T. 20 N. R. 62 E. CLARKE County
 PERMIT NO. 14009101001 Parcel No. NELLIS A.F.B. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other SMALL

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>KT-BRN FINE SAND</u>		<u>1</u>	<u>7.7</u>	<u>7.7</u>
<u>BRN CLAY, SILT FINE SAND</u>		<u>7.7</u>	<u>34</u>	<u>26.3</u>
<u>BRN CLAY, CALICHE</u>		<u>37</u>	<u>78</u>	<u>41</u>

8. WELL CONSTRUCTION
 Depth Drilled 78 Feet Depth Cased 77 Feet

HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 78 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>6CM40</u>	<u>PVC</u>	<u>0</u>	<u>77</u>

Perforations:
 Type perforation SLOTTED
 Size perforation .020
 From 77 feet to 77 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 45 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 45 feet to 77 feet

9. WATER LEVEL
 Static water level 41.87 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 9/30, 2006
 Date completed 10/1, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name PROSONIC CORP Contractor
 Address 12464 MCCANN DR Contractor
SANTA FE SPRINGS CA. 90670
 Nevada contractor's license number issued by the State Contractor's Board 0051765
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2303
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 10/26/06