

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



office use only
Log No. 101410
Permit No.
Basin 269

NOTICE OF INTENT NO 57319

1. OWNER **Thomas McMeekin** ADDRESS AT WELL LOCATION **3005 Eastlake Blvd.**
MAILING ADDRESS **3005 Eastlake Blvd.** Latitude **N 39.17.703** WGS 84
Carson City, NV 89704 Longitude **W 119.46.529**
2. Location **NW 1/4 SE 1/4 31 Sec T17 N R20 E** **Washoe County**
PERMIT NO. PARCEL NO. **050-401-10** SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
New Well	<input checked="" type="checkbox"/> Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	<input checked="" type="checkbox"/> Mud

6. LITHOLOGIC LOG				8. WELL CONSTRUCTION						
Material	Water Strata	From	To	Thickness	Depth Drilled	HOLE DIAMETER (BIT SIZE)	Depth Cased			
Sand		0	60	60	11 inches	0	50 feet			
D.G. Sand		60	240	180	8 3/4 inches	50	240 feet			
Granite		240	270	30	8 1/8 inches	240	305 feet			
Fractured Granite		270	275	5	CASING SCHEDULE					
Granite		275	295	20	Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)	
Fractured Granite		295	305	10	0	6 5/8	12.94	.188	0	240
				0	0	5 9/16	10.7	.188	240	305
				0	Perforations:					
				0	Type Perforation	Factory				
				0	Size perforation	3/32 x 3"				
				0	From	200	feet to	240	feet	
				0	From	285	feet to	305	feet	
				0	From		feet to		feet	
				0	From		feet to		feet	
				0	From		feet to		feet	
				0	From		feet to		feet	
				0	Surface Seal	<input checked="" type="checkbox"/> YES	No	Seal Type:		
				0	Depth of Seal	50	feet	Neat Cement		
				0				<input checked="" type="checkbox"/> Cement Grout		
				0				Concrete Grout		
				0	Gravel Packed:	<input checked="" type="checkbox"/> Yes	No			
				0	From	240	feet to	50	feet	
				0	9 WATER LEVEL					
				0	Static water level	80	feet below	land surface		
				0	Artesian flow	0	GPM	0	P.S.I.	
				0	Water Temperature	cold	Degrees F	Quality good		

39.295155 °N
119.774482 °W
NAD83 Cont US

Date started **6/22 -06**
Date completed **6/27 -06**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (hours)	
10	40		.5	
15	100		.5	
25	160		.5	
35	220		2	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. **14170**
NV Driller's Lic (on site) **2187**
Signed *Steve McKay*
By driller performing actual drilling on site or contractor
Date **6/29 -06**

STATE ENGINEERS OFFICE

2006 SEP 22 PM 1:21

RECEIVED