


STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT



office use only  
Log No. 101415  
Permit No. \_\_\_\_\_  
Basin 692E

NOTICE OF INTENT NO 58383  
6540 Meyers 57007

1. OWNER **McKay Properties**  
MAILING ADDRESS **4850 Joule St STE A-5**  
**Reno, NV 89502**

ADDRESS AT WELL LOCATION  
Latitude N 39.36.179  
Longitude W 119.51.368

2. Location SE 1/4 NW 1/4 16 Sec T20N N R19 E **Washoe County**  
PERMIT NO. \_\_\_\_\_ PARCEL NO. **082-660-15** SUBDIVISION NAME \_\_\_\_\_

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	<input checked="" type="checkbox"/> Air	Other	Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay.		0	3	3
Clay & small gravel.		3	325	322
Blue lime stone.		325	385	60

8. WELL CONSTRUCTION

Depth Drilled	385 feet	Depth Cased	385 feet
HOLE DIAMETER (BIT SIZE)			
	From	To	
11 inches	0 feet	65 feet	feet
8 3/4 inches	65 feet	385 feet	feet
			feet
CASING SCHEDULE			
Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)   To (Feet)
6 5/8	12.94	188	+1 1/2   385
Perforations::			
Type Perforation	Factory		
Size perforation	3/32 x 3"		
From	325 feet	to	385 feet
From		to	feet
From		to	feet
From		to	feet
From		to	feet
From		to	feet
From		to	feet
Surface Seal	<input checked="" type="checkbox"/> YES	No	Seal Type:
Depth of Seal	65 feet		Neat Cement
		Pumped	<input checked="" type="checkbox"/> Cement Grout
		x Poured	Concrete Grout
Gravel Packed:	<input checked="" type="checkbox"/> Yes	No	
From	65 feet	to	385 feet

39.603094 °N  
119.855125 °W  
NAD27 Co. US

9. WATER LEVEL

Static water level	270 feet	below land surface
Artesian flow	0 GPM	0 P.S.I.
Water Temperature	cold	Degrees F
		Quality

Date started 6-23 -06  
Date completed 6-30 -06

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (hours)	
12	45		1	
30	110		1.5	

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**  
NV Contractors No. **14170**  
NV Driller's Lic (on site) **2292**  
Signed *Steve McKay*  
By driller performing actual drilling on site of contractor  
Date 7-16 -06

STATE ENGINEERS OFFICE

2006 SEP 22 PM 1:21

RECEIVED