

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT



office use only  
Log No. 101917  
Permit No.  
Basin 029

NOTICE OF INTENT NO 57296  
7445 Bryan Canyon Road

1. OWNER **Bob Watson**  
MAILING ADDRESS **7445 Bryan Canyon Road**  
**Washoe Valley, NV**

ADDRESS AT WELL LOCATION  
**39 deg 13.776' N WGS 84**  
**119 deg 49.594' W**

2. Location **NW 1/4 NW 1/4 Sec 26 T 18N R 19E**  
PERMIT NO. **PARCEL NO. 055-292-29**

**Washoe County**  
SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
<input checked="" type="checkbox"/> Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	<input checked="" type="checkbox"/> Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granite		600	620	20
Fractured granite.		620	626	6
Granite		626	640	14
Fractured granite		640	642	2
Granite.		642	682	40
Fractured granite.		682	700	18

8. WELL CONSTRUCTION

Depth Drilled	700 feet	Depth Cased	700 feet
HOLE DIAMETER (BIT SIZE)			
	From	To	
6 1/8 inches	500 feet	700 feet	
CASING SCHEDULE			
Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet) To (Feet)
0 6 5/8	12.94	188	+1 1/2 600
0 5 9/16	10.7	188	590 700
Perforations::			
0	Type Perforation	Factory	
0	Size perforation	3/32 x 3"	
0	From	500 feet to 700 feet	
0	From	feet to feet	
0	From	feet to feet	
0	From	feet to feet	
0	From	feet to feet	
0	From	feet to feet	
0	Surface Seal	<input checked="" type="checkbox"/> YES No	Seal Type:
0	Depth of Seal	100 feet	Neat Cement
0		Pumped	<input checked="" type="checkbox"/> Cement Grout
0		<input checked="" type="checkbox"/> Poured	Concrete Grout
0	Gravel Packed:	<input checked="" type="checkbox"/> Yes No	
0	From	100 feet to 700 feet	

39.229705° N  
119.825565° W  
NAD 27 Cont US

9. WATER LEVEL

0	Static water level	160 feet below land surface
0	Artesian flow	0 GPM 0 P.S.I.
0	Water Temperature	cold Degrees F Quality

Date started **6-2 -06**  
Date completed **6-16 -06**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)			Time (hours)
10	240			
15	400			
30	540			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**

NV Contractors No. **14170**  
NV Driller's Lic (on site) **2187**

Signed Steve McKay  
By driller performing actual drilling on site of contractor

Date **9-23 -06**

STATE ENGINEERS OFFICE

2006 SEP 22 PM 1:21

RECEIVED