COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101431
Permit No.
Basin 093

NOTICE OF INTENT NO. 50542

1. OWNER STEPHENS HAASS WILLIAM C & BETTY JO
MAILING ADDRESS P.O.BOX 61293
RENO, NEVADA. 89506

ADDRESS AT WELL LOCATION 1210 ALUM ROCK RD
RENO, NEVADA. 89506
GPS: UTM UPS.NAD27 CONUS. 11S 0258416 . UTM 4407424

2. LOCATION SE ¼ SW ¼ Sec 11 T 22 N R 19 E WASHOE County

PERMIT NO. N/A (Issued by Water Resources) | 079-500-10 (APN) | RED ROCK ESTATES (ANTELOPE VALLEY) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	3	3
D.G (BROWN)	99	3	135	132
D.G (GRAY)		135	200	65

RECEIVED 2006 AUG 28 AM 11:18 STATE ENGINEERS OFFICE

Date started 02-25 , 20 006

Date completed 07-15 , 20 006

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	10	8

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	STEEL	.188	+2	8
6 5/8	P.V.C	SDR 21, F480	8	200

Perforations:
Type perforation SCREEN
Size perforation .065
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No ☐ 30% Grout
From 100 feet to 200 feet

9. WATER LEVEL
Static water level 99 feet below land surface
Artesian flow N/A G.P.M N/A P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WILLIAM GEORGE MOSEGAARD WELL DRILLING (CONTRACTOR)
Address 1223 ALUM ROCK RD)(MAILING ADDRESS P.O. BOX 61075 (CONTRACTOR)
RENO, NEVADA. 89506
Nevada contractor's license number issued by the State Contractor's Board 0053579
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2211

Signed William H Mosegaard 8-14-2006
By driller performing actual drilling on site or contractor

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com