COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101435
Permit No.
Basin 103

NOTICE OF INTENT NO. 58204

1. OWNER SCOTT SNELLING CONSTRUCTION
MAILING ADDRESS 318 SYDNEY DR
DAYTON, NV 89403

ADDRESS AT WELL LOCATION 6970 IRON MTN BLVD
STAGE COACH, NV

2. LOCATION ~~NE~~ SW ¼ ~~NE~~ SW ¼ Sec ~~1~~ 07 T 17 N R 22 E LYON County

PERMIT NO. Issued by Water Resources | 015-352-11 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
VOLCANIC BOULDERS		0	36	36
VOLCANIC GRAVELS		36	135	99
BROWN CLAY		135	185	50
VLOCANIC GRAVELS		185	213	28
FRACTURED GRAVELS	XX	213	260	47

GPS INFO:
39.34643*N NAD83
119.44896*W

Date started 9/14, 20 06
Date completed 9/17, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	50	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 260' Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	260 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr21	4.06	.216	20	260

Perforations:
Type perforation SAW CUT
Size perforation 3 3/32
From 220 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 135 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 10/12/06