REPORT NO. A06.063

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 101436
PERMIT NO.
BASIN 090

NOTICE OF INTENT NO. 57955

1. OWNER Sierra Nevada College
MAILING ADDRESS 291 Country Club Dr,Incline Village, NV 89451
ADDRESS OF WELL 291 Country Club Dr
Incline Village, NV 89451

2. WELL LOCATION NE 1/4 NE 1/4 SEC. 22 T 16N R 18 E Washoe COUNTY
PERMIT NO M/O 1410.A PARCEL NO 127-040-10 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Multi Color Rock Clay Sand				
Dirt & Rock Fill		0	5	5
D.G.		5	10	5
Multi Color Rock Clay Sand		10	12	2
Some Cobels Sands, Yellow Clay		12	27	15
Soft Weathered Gran Ylw Gray Clay		27	45	18
Thick Gray & Yellow Sand & Clay		48	50	5
Gray Gran, Yellow Gray Clay Sand		50	100	56
Yellow Gray Clay, Weathered Gran		100	146	46
Harder Weathered Gran Silty Clay		146	152	6
Gray Yellow Clay, Weathered Gran		152	193	41
Harder Gractured Gran, Less Clay		193	289	91
Hard Granite Light Bl-Grn-Gry Clay		284	298	19

2006 SEP 27 AM 10:58

Notes: Latitude: N39 14.552 Longitude: W119 56.384 WGS-84
39.242639 °N
119.938728 °W NAD27 Con US

Date Started 07/26/06 Date Completed 07/31/06

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		1.5

8. WELL CONSTRUCTION
Depth Drilled 298' Depth Cased 298'

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 100 Feet
~~8 1/2~~ Inches 100 Feet 298 Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.96	.188	+2	298

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 238 Feet to 278 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 100'
PLACEMENT METHOD: [X] Pumped [ ] Poured

SEAL TYPE:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 100 Feet to 298 Feet

9. WATER LEVEL
Static Water Level 62 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2189
Signed Roger Mitchell
By driller performing actual drilling on site or contractor
Dated Aug 14 / Sept 25 - 2006