

mw-1

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

RECEIVED
Log No. 101458
Permit NCEP 1-5-2006
Basin 087
ENVIRONMENTAL PROTECTION
NOTICE OF INTENT NO. 56422

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER CITY OF RENO ADDRESS AT WELL LOCATION 111 MORELL RD RENO, NV
 MAILING ADDRESS 264 KEYSTONE AVE RENO, NV

2. LOCATION SE 1/4 NW 1/4 Sec 12 T 19 N R 19 E WASHOE County
 PERMIT NO. D-00100 (NCEP*) 008-360-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SILT		0	4	4
GRAVEL + SAND + SILT		4	8	4
GRAVEL + SAND		8	16	8
SAND		16	20	4
SAND + SILT		20	21	1
SAND + GRAVEL		21	26	5
GRAVEL + CLAY	✓	26	31	5
GRAVEL + SAND + SILT	✓	31	40	9
SAND + SILT	✓	40	46	6
SAND + GRAVEL	✓	46	48	2
SAND + SILT	✓	48	50	2

39° 31 min 48 sec N
119° 48 min 08 W

RECEIVED
2006 SEP 19 PM 11:00
STATE ENGINEERING DIVISION

MAAD 83

8. WELL CONSTRUCTION
 Depth Drilled 50 Feet Depth Cased 48 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6" Inches	0	48
4" Inches	0	50

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Col 40	.308"	0	28

Perforations:
 Type perforation FACTORY CUT
 Size perforation 0.010
 From 48 feet to 28 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 28

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 26 feet

9. WATER LEVEL
 Static water level 28 FT feet below land surface
 Artesian flow NO G.P.M. P.S.I.
 Water temperature..... °F Quality.....

Date started 8-24, 2006
 Date completed 8-24, 2006

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BOART LONGYEAR CO Contractor
 Address 7773 WEST SELDON LN Contractor
PEORIA, AZ 85345

Nevada contractor's license number issued by the State Contractor's Board 6016157
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2270

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8-24-06

RECEIVED
2006 OCT 10 PM 1:30
STATE ENGINEERS OFFICE