

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1375

1. OWNER JACK CARRINGTON ADDRESS AT WELL LOCATION HIGHLAND ROAD
 MAILING ADDRESS 560 ARROYO RENO, NV. 89509 VIRGINIA HIGHLANDS

2. LOCATION NW 1/4 SW 1/4 Sec 5 T 21 N R 17 E STOREY County
 PERMIT NO. 003-421-16 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Altered Volcanic		0	94	94
Andisite - Black - hard		94	196	102
Formation softer - greenish rock-fractured	X	196	241	45
T. D. 241 ft.				
There is a 6 ft. blank on bottom of casing for development				

8.10 5/8 - 50" WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 241 feet
 Casing record 6 5/8
 Weight per foot 10.78 Thickness .156
 Diameter 6 5/8 inches From +18 feet To 241 feet
 Surface seal: Yes No Type Grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 241 feet
 Perforations:
 Type perforation Factory
 Size perforation 3/32 X 3
 From 235 feet to 235 feet
 From 213 feet to 235 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 156 feet below land surface
 Flow 15 G.P.M. _____ P.S.I.
 Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AQUA DRILLING & WELL SERVICE, INC.
 Address 2255 GLENDALE AVE. = SPARKS, NV. 89431

Date started 5-26, 1983
 Date completed 5-31, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with air to clean & develop			

Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
 Actual Driller

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

Signed Roger M Thrall
 Roger M. Thrall Contractor
 Date 5-31-83

STATE ENGINEERS OFFICE

RECEIVED

JUN 14 1983

JUN 14 1983

STATE ENGINEERS OFFICE

STATE ENGINEERS OFFICE

JUN -6- AMT:14 83