COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101476
Permit No.
Basin 071

NOTICE OF INTENT NO. 55635

1. OWNER Robert Dickenson
MAILING ADDRESS PO Box 6887
Reno, NV 89513

ADDRESS AT WELL LOCATION 14700 S. Grass Valley Road
Winnemucca, NV 89445

2. LOCATION N1/2 ¼ W1/2 ¼ Sec 19 T 34 N R 38 E Pershing County

PERMIT NO. (Issued by Water Resources) | Parcel No. 09-250-14 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Cobles		0	10	10
3/4 Gravel		10	70	60
Boulders		70	110	40
Gravel & Sand	X	110	120	10
Cobles		120	170	50
Sand & gravel	X	170	215	45
Boulders		215	220	5

RECEIVED 2006 AUG 23 AM 11:31 STATE ENGINEERS OFFICE

Date started March 13, 20 06
Date completed March 15, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		6

8. WELL CONSTRUCTION

Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	220 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	20
6.625	4.06	.316	20	220

Perforations:
Type perforation Factory cut
Size perforation 0.50
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 110' ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 110 feet to 220 feet

9. WATER LEVEL

Static water level 143 feet below land surface
Artesian flow N/A G.P.M N/A P.S.I
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fred Anderson & Sons Drilling, Inc. (CONTRACTOR)
Address 10760 Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083

Signed
By driller performing actual drilling on site or contractor
Date March 20, 2006

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com