WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101492
Permit No.
Basin 071

NOTICE OF INTENT NO. 51306

1. OWNER Ed Klemish
MAILING ADDRESS 4085 East Thomas Canyon Rd Winn NV 89445
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SW ¼ Sec. 7 T. 35 N/S R. 38 E. Humboldt County
PERMIT NO. (Issued by Water Resources) 10-483-07 (Parcel No.) Sonoma Ranches (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	2	2
Sand + Gravel		2	80	78
Clay		80	90	10
Boulders + Sand		90	130	40
Fractures lost circulation		130	145	15
Boulders		145	160	15
Gravel + Sand	7	160	165	5
Sand + Boulders		160	180	20
Sand + Gravel	33	180	210	30

RECEIVED 2006 AUG 23 AM 11:30 STATE ENGINEERS OFFICE

Date started Nov. 10 2003
Date completed Nov. 14 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		4

8. WELL CONSTRUCTION
Depth Drilled 210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	145	Feet
6 1/4	Inches	145	Feet	220	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	1.88	+1	145
5"	7	1.88	140	210

Perforations:
Type perforation ~~Slot~~ Factory Cut
Size perforation 3/32X4
From 180 feet to 210 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 145 feet

9. WATER LEVEL
Static water level 140' feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson + Son Drilling (Contractor)
Address 10760 S. Grass Valley Rd (Contractor)
Winn NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed (By driller performing actual drilling on site or contractor)
Date Nov. 15, 2003

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627