WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101493
Permit No.
Basin 071

NOTICE OF INTENT NO. 45188

1. OWNER Dave Delong
MAILING ADDRESS 3410 E. Thomas Canyon
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 3410 East Thomas Canyon
Winnemucca NV 89445

2. LOCATION NW ¼ Bog N ¼ NE ¼ Sec. 13 T. 35 N/S R. 37 E. Humboldt County
PERMIT NO. N/A (Issued by Water Resources) Parcel No. 013-541-06 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		100	110	10
Gravel		110	150	40
Cobles + Gravel		150	160	10
Clay		160	165	5
Sand + Gravel		165	179	14
Solid Rock		179	181	

Existing → 8⅝

RECEIVED 2006 AUG 23 AM 11:30 STATE ENGINEERS OFFICE

Date started Sept 12, 2006
Date completed Sept 15, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		3

8. WELL CONSTRUCTION
Depth Drilled 81 Feet Depth Cased 181' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7⅞ Inches		104 Feet	181 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	10	188	100	81
8⅝	15	188	+1	100

Perforations:
Type perforation Factory Cut
Size perforation 3/32x3
From 66 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal Existing Well
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From Existing feet to Existing feet

9. WATER LEVEL
Static water level 107' feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Sons Drilling (Contractor)
Address 10760 Grass Valley Rd (Contractor)
Winn NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Sept 15, 2006

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627