WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101495
Permit No.
Basin 070

NOTICE OF INTENT NO. 44414

1. OWNER Paul Miller
MAILING ADDRESS 711 Maple Street Winn, NV 89445

ADDRESS AT WELL LOCATION 1.625 miles NW of Rose Creek water change

2. LOCATION SE ¼ NW ¼ Sec. 22 T. 35 N/S R. 36 E Humboldt County
PERMIT NO. 70686-T (Issued by Water Resources) 05-491-27 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Exploration

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	2	2
Clay		2	50	48
Sand + Gravel		50	100	50
Hard Rock		100	130	30
Fractured Rock	10 GPM	130	135	5
Black hard Rock		135	160	25
Sand + Gravel	XX	160	180	20
Clay + Rock		180	190	10
Red Clay		190	210	20
Tan Clay		210	240	30
Red Clay		240	350	10
Rock w Clay		350	460	110
Fine Rock Red Clay		460	560	100

Drill To 300' with 10 5/8 Set Pipe Get H2O Sample with Air. Drill out Bottom To 560' No more water zones pump 9 Sacks Abandonite

Check Static at 60' pump 24 Sacks Abandonite Pull Pipe Pour 10 Sack 3/4 hole plug + Native material To 20' pump 10 Sacks Neat Cement To Surface

This Took A little while Because we were waiting on Test Results + Scheduling of A Rig There is No hole here To much Boron

Date started Feb 26, 2004
Date completed Sept 6, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200		

RECEIVED 2006 AUG 23 AM 11:30 STATE ENGINEER

8. WELL CONSTRUCTION
Depth Drilled 560 Feet Depth Cased 300 Then pulled Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	300 Feet
5 1/8 Inches	300 Feet	560 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	.188	+1	300

Perforations:
Type perforation Factory Cut
Size perforation 3/32 mill Slot
From 260 feet to 300 feet
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow No G.P.M. 100 P.S.I.
Water temperature Cool °F Quality Lots of Boron

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson
Contractor
Address 10760 Grass Valley Road
Contractor
Winn, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 21467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375
Signed
By driller performing actual drilling on site or contractor
Date March 10 2004

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627