COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101522
Permit No.
Basin

NOTICE OF INTENT NO. 58214

1. OWNER JON RAFT C/O CVC INC.
MAILING ADDRESS P.O. BOX 56
CLAIRE MONT CA, 91711

ADDRESS AT WELL LOCATION 85 VIOLA WAY
CARSON CITY , MN 89704

2. LOCATION SE ¼ NW ¼ Sec 23 T 17 N R 19 E WASHOE County

PERMIT NO. WASHOE # 060076 (Issued by Water Resources) | 050-234-58 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
BROWN SANDS		3	15	12
COURSE GRAVELS		15	91	76
GRAY CLAY		91	136	45
GRAY CLAY BALLS				
SMALL GREEN COLOR	XXX	136	180	44
SANDS DG GRAVELS				

GPS INFO: Closer to 39° 19.3810
39.32223*N 119° 48.8609
119.81464*W ~~NAD27~~ NAD27
. NAD 83

Date started 8/3 , 20 06
Date completed 8/4 , 20 06

7. WELL TEST DATE
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	30	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8sdr 21	4.06	.216	20	180

Perforations:
Type perforation SAW CUT
Size perforation 3X 3/32
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 180 feet

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M 25+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 8/9/06

RECEIVED 2006 AUG 11 AM 11:45 STATE ENGINEERS OFFICE