REPORT NO. A06.073

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

I

LOG NO. 101523
PERMIT NO.
BASIN Ø84

NOTICE OF INTENT NO. 57960

1. OWNER Roy Johnson
MAILING ADDRESS P.O. Box 3977, Sparks, NV 89432

ADDRESS OF WELL 305 Red Corral Trail
Reno, NV 89510

2. WELL LOCATION NE 1/4 SW 1/4 SEC. 08 T 21N R 22 E Washoe COUNTY

PERMIT NO _____ PARCEL NO 77-410-15 SUBDIVISION NAME _____

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Green Brown Clay Dirt VR		0	10	10
Gray Sandy Clay Reddish Color		10	50	40
Blue Clay, Blue Green Clay		50	110	60
Purple Clay Blue Green VR		110	240	130
Dark Gray & Blue Fractered VR		240	340	100
Gray Clay Gray Blue VR		340	380	40
Blue Gray Black Yellow VR		380	406	26
Gray Blue Green Sandy Clay & VR		406	467	61
Dark Reddish, Dark Green & VR		467	483	16
& Multicolored Clay		483		
Orange Green Sandy Clay		483	494	11
Lt Gray clay Bl Grn Sandy Clay		494	575	81
Multicolor Clay		575	610	35
Light Gray sandy Clay		610	620	10
Sitty Gray Clay Sandy Gravel		620	664	44
Gray Rock No Clay		664	730	66
Gray Blue & Green VR		730	860	130
VR W/ Specs of Gray Clay		860	905	45
VR Some Black Chips		905	954	49

Notes : WGS-84 GPS: Latitude: N39 41.930 Longtitude: W119 32.411
Well #1.

~~36~~ 39.698443°N
119.539182°W
NAD27 Con US

Date Started 08/16/2006 Date Completed 08/30/2006

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	0		4.5

8. WELL CONSTRUCTION

Depth Drilled 954' Depth Cased 698'

HOLE DIAMETER (BIT SIZE)

10 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 698 Feet
6 1/2 Inches 698 Feet 954 Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	698'

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From _____ Feet to _____ Feet
From 618 Feet to 698 Feet
From _____ Feet to _____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [ ] Pumped [X] Poured
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout [ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 698 Feet

9. WATER LEVEL
Static Water Level ~~None~~ dry Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature _____ F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2189

Signed Roger M Thrall
By driller performing actual drilling on site or contractor

Dated October 10, 2006

RECEIVED
2006 OCT 13 AM 11:26
STATE ENGINEER'S OFFICE