



Log No. 101541
 Permit No.
 Basin 106

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO.

1. OWNER Ron Cornes ADDRESS AT WELL LOCATION East Side In
 MAILING ADDRESS P.O. Box 550446 North Reno Canyon
South Lake Tahoe Reese
 2. LOCATION NE 1/4 SE 1/4 Sec. 8 T. 9 N/S R. 23 E. Douglas County
 PERMIT NO. 092308000-006 Parcel No. Subdivision Name

3. WORK PERFORMED: New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE: Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE: Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard pan rock		0	4	4
clay		4	12	8
Sand & Gravel		4	12	8
Coarse Gravel & Clay		12	40	28
Clay + fine gravel		40	80	40
Brown Clay		80	160	80
Gravel		160	190	30
Brown clay & gravel		180	250	70
more fine		250	270	20
blue clay		270	300	30
green clay		300	340	40
gray clay		340	375	35
thin gravel	yes	375	420	45
coarse gravel	yes	420	460	40

8. WELL CONSTRUCTION
 Depth Drilled 460 Feet Depth Cased 460 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 460 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>1.85</u>	<u>0</u>	<u>420</u>
<u>5</u>		<u>F 480</u>	<u>420</u>	<u>460</u>

Perforations:
 Type perforation Factory
 Size perforation 3/32 x 3
 From 380 feet to 460 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 30 feet to 460 feet

UTM E 0299113
 N 4280962
 NAD27

Date started July 22 2006
 Date completed Aug 9 2006

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>6</u>	<u>7.5</u>	<u>4</u>

9. WATER LEVEL
 Static water level 400 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature calc F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edmund Miller Drilling
 Address P.O. Box 92 Smith Pl.
89430
 Nevada contractor's license number 32166 A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 718
 Division of Water Resources, the on-site driller.
 Signed Edmund Miller
 By driller performing actual drilling on site or contractor
 Date Aug 11 - 06

RECEIVED
 2006 AUG 14 AM 11:28
 STATE ENGINEERS OFFICE