WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 121557
Permit No.
Basin 179

NOTICE OF INTENT NO. 51410

1. OWNER Wendy Paris
MAILING ADDRESS P.O. Box 150818
Ely, Nevada 89315
ADDRESS AT WELL LOCATION Approximately 5 Miles NW of Ely

2. LOCATION ~~SW NE~~ ¼ ~~NE SW~~ ¼ Sec. 15 T. 17 N. R. 63 E. White Pine County
PERMIT NO. (Issued by Water Resources) Lot 58 APN 005-571-19 (Parcel No.) Cross Timbers (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Sand & Gravel with		4		
Clay Stringers			35	31
Sand & Gravel		35	50	15
Brown Clay		50	55	5
Sand & Gravel		55	85	30
Clay & Gravel		85	90	5
Water Sand	X	90	95	5
Clay & Small Gravel		95	110	15
Clay & Course Gravel		110	140	30
Sand & Gravel with		140		
Clay Stringers			150	10
Course Gravel	X	150	160	10
Sand & Gravel		160	175	15
Brown Clay		175	180	5

RECEIVED 2006 AUG 21 AM 10:57 STATE ENGINEERS OFFICE

Latitude N 39° 20' 13.0"
Longitude W 114° 52' 31.8"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

Date started June 5, 2006
Date completed June 6, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100	86	1

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	180 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	180

Perforations:
Type perforation Factory
Size perforation 1/8" X 2½" 6 Rows
From 80 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 Ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 89 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, Nevada 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed Rich Lewis By Jerald D. Christiansen
By driller performing actual drilling on site or contractor
Date July 5, 2006

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627