WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101558
Permit No.
Basin 1373

NOTICE OF INTENT NO. 57665

1. OWNER Round Mountain Gold Corp.
MAILING ADDRESS PO Box 480
Round Mountain, NV 89045

ADDRESS AT WELL LOCATION Round Mountain Gold
PO Box 480
Round Mountain, NV 89045

2. LOCATION SW ¼ NW ¼ Sec. 15 T. 10 N/S R. 43 E. Nye County
PERMIT NO. NEV 41030 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other

6. MW-112 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium Sand, Silt, and clay		100	0	100
Native fill		100	85	15'
#8 Sand		85'	52	33'
7 - Super sacks				
3/8 Pea gravel		52	40	12'
4 - super sacks				
3/8 Bentonite chips		40	20	20'
3 - super sacks				
Neat cement		20	+1	21'
8 - 94# bags				
GPS		N38° 43' 44.88"		
		W117° 08' 46.01"		
Map Datum		NAD83		

Date started 7/14, 2006
Date completed 7/19, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
At TD.	25		

8. WELL CONSTRUCTION
Depth Drilled 100' Feet Depth Cased 85' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 3/4" Inches		19 Feet	0 Feet
8 3/4" Inches		100 Feet	19 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4"		1/4" wall	19	+1
4 1/2		1/4" PVC	85	+2

Perforations:
Type perforation Horizontal
Size perforation .020
From Perforated 85 feet to 45 feet
From feet to feet
From Blank 45 feet to +2 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 85' feet to 40' feet

9. WATER LEVEL
Static water level 51' feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature Cold °F Quality Slightly murky

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Inc. (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1698-T1
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7/19/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627