COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101560
Permit No.
Basin 105

NOTICE OF INTENT NO. 58219

1. OWNER HEATHER TOPP
MAILING ADDRESS 1302 MEYERS DR
GARDNERVILLE , NV 89410

ADDRESS AT WELL LOCATION 1302 MEYERS DR
GARDNERVILLE , NV 89410

2. LOCATION ~~NW~~ NE ¼ SW ¼ Sec 5 T 12 N R 21 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | 1221-05-002-033 (Parcel No.) | FISH SPRING AREA (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 8 5/8 WELL 92'		0	92	92
BROWN CLAY		92	105	13
COURSE GRAVELS		105	156	51
BROWN CLAY		156	165	9
GRAVELS , SANDS	XX	165	192	27

GPS INFO:
38.93205° N
119.65467° W
NAD83

Date started 8/26 , 20 06
Date completed 8/27 , 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+	35	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 192 ~~100~~ Feet Depth Cased 192 ~~100~~ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7 7/8 Inches	92 Feet	192 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	82	192

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 152 feet to 192 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No Seal Type:
Depth of Seal N/A ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 25 feet below land surface
Artesian flow G.P.M 30+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 8/28/06

RECEIVED

2006 SEP -6 AM 10: 53

STATE ENGINEERS OFFICE