

Log No. 10561  
 Permit No. \_\_\_\_\_  
 Basin 1373

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57030

1. OWNER Round Mountain Gdd Corp  
 MAILING ADDRESS P.O. Box 480  
 Round Mountain, NV 89045  
 ADDRESS AT WELL LOCATION Round Mountain  
 P.O. Box 480  
 Round Mountain, NV 89045  
 2. LOCATION SE 1/4 NW 1/4 Sec. 15 T. 10 N. S. R. 43 E. Nye County  
 PERMIT NO. NEV 91030  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. MW-111 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Aluminum sandstone silt and clay		100	0	100
Native fill		100	92	8'
#8 Sand 2- super sacks		42	40	52'
3/8" Bentonite chips 1 1/2 super sacks		40	20	20'
New concrete 8- 94# bags		20	21	21'

GPS N 38° 43' 43.64"  
 W 117° 08' 22.026  
 Map Datum NAD83

8. WELL CONSTRUCTION 92'  
 Depth Drilled 100' Feet Depth Cased 92' Feet  
 HOLE DIAMETER (BIT SIZE)  
 14 3/4" From 0 Feet To 19 Feet  
 8 1/2" Inches 19 Feet 100 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4		1/4" steel	21	19
4 1/2		1/2" PVC	22	92'

Perforations:  
 Type perforation Horizontal slot  
 Size perforation .020  
 From Screen 92' feet to 52' feet  
 From Blank 52' feet to 22 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 20'  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 92' feet to 40 feet

Date started 7/10 2006  
 Date completed 7/14 2006

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
A+ TD	17		

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow NA G.P.M. NA P.S.I.  
 Water temperature Cold °F Quality Slightly murky

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ek Ind Drilling Inc.  
 Address P.O. Box 2748  
 Elko, NV 89803  
 Nevada contractor's license number issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1698-T1  
 Signed John  
 By driller performing actual drilling on site or contractor  
 Date 7/15/06