WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 101576
Permit No.
Basin 070

NOTICE OF INTENT NO. 55661

1. OWNER Eileen Bailey
MAILING ADDRESS 4655 Piper Lane
Winca NV 89445
ADDRESS AT WELL LOCATION 4655 Piper Lane

2. LOCATION lot 8, Block B Sec. 23 T. 35 N/S R. 37 E Humboldt County
PERMIT NO. (Issued by Water Resources) Parcel No. 014-083-08 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Gravel + Sand | | 95 | 115 | 20 |
| Clay | | 115 | 125 | 10 |
| Sand + Gravel | X | 125 | 130 | 5 |
| Clay | | 130 | 150 | 20 |
| Sand + Fine Gravel | X | 150 | 180 | 30 |
| Clay | | 180 | 185 | 5 |

N 40° 53.714'
W 117° 47.216'
elev 4311
WGS 84

RECEIVED 2006 AUG 23 AM 11:29 STATE ENGINEER'S OFFICE

Date started June 14, 2006
Date completed June 16, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | 77 | 4 |

8. WELL CONSTRUCTION
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 7 3/4 | Inches | 95 Feet | 185 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 10 | .188 | 85 | 185 |

Perforations:
Type perforation Factory cut
Size perforation 5/32 X 4
From 125 feet to 135 feet
From 165 feet to 185 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal Existing
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From Natural feet to feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson + Sons (Contractor)
Address 10760 Grass Valley Rd (Contractor)
Winn NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed (By driller performing actual drilling on site or contractor)
Date July 26, 2006

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627